



ADDENDUM NO. 1
IFB#3-2014/2015 GCSC Central Plant

Addendum for GCSC Central Plant IFB#3-2014/2015 is amended in the following particulars and in these particulars only. All provisions of the original documents shall remain in force, except as specifically modified or changed herein or by other Addenda issued by GCSC. This Addendum is hereby made part of the Contract Documents of the IFB.

RESPONSE TO WRITTEN QUESTIONS RECEIVED:

Question #1: Is there a budget or construction estimate by the college?

- ❖ **No, the intent is for bidders to provide cost of project to college.**

Question #2: Sheet S101 show background notes stating concerning trench drains, downspouts, lockers, concrete sidewalks and etc. Are item notes to be included in pricing? Is the only work to be included on from sheet notes are existing lintel repairs and structural steel?

- ❖ **Per Engineer; The general notes have some typical notes that do not apply to this particular job. The scope of the work is for lintel repair and louver replacement as shown on the details. There is also some work involving wall cap repair as shown on the details. Disregard notes pertaining to trench drains, downspouts, lockers, concrete sidewalks.**

March 11, 2015 at 4:00PM was the last date and time vendor can submit questions on this project. All vendors are responsible for receiving and reading Addendums on project. All Addendums will be post at gulfcoast.edu/procurement.

Fred Brown, Procurement Director

Signature